



ADDENDUM # 01

Acknowledge receipt of this addendum
on the bid form and the bid envelope

Project Name: **DNRC Regional Office
Missoula DNRC / SWLO
New Helicopter Hanger**
Bid No. 115010 CSW
Project Location: **3150 Maverick Drive
Missoula MT, 59804**
Date: **July 8, 2010**

Civil Work:

Item 1: Change

Replace sheet A1.0 of the Bid Set with the attached Revised A1.0 Sheet dated 7-8-10 in the revision box. The Revised A1.0 includes the removal of the grease interceptor and sump. Install in its place a closed bottom sump with an 8" diameter cleanout and cap extended to grade. The sump shall have a 30" inside diameter dimension by 4 feet high. The sump shall be constructed of reinforced concrete and vented to meet the requirements of the Uniform Plumbing Code. The sump shall be manufactured by "Hunton Pre-Cast Concrete Inc." 1700 Rodgers St, Missoula, MT, 59802; (406) 543-8640.

Architectural:

Item 1: Bid Form

Replace the Bid Set "Bid Form" with the attached Revised Bid Form Dated 7-8-10.

Item 2: Fax Bid Form Modifications

The Bid Forms may be fax modified as long as the bid modifications are received by the time Bidding is closed. Bid Modifications may be faxed to 406-444-2684 attention Jeff Williams. Sealed Modified Bid Forms shall be provided to the Contract Administrator no later than 24 hours after Closing of the bid. It is the Bidders sole responsibility to ensure the modifications and modified bid forms are received by the Contract Administrator.

Item 3: Section 072100 Thermal Insulation

The rigid insulation shall be changed to Type IV 25 PSI insulation with a minimum R-value of 10 in the 2" thickness. The insulations shall be rated to buried against a foundation.

Item 4: Detail 3/A3.1

The note "~~Endwall Bracing~~" shall be changed to read "**2x6 Endwall Bracing @ 48" o.c. with A35 clips at each end.**" This note shall supercede all other endwall bracing notes.

Structural:

Item 1: Detail 2/S2.0 Change

The Anchor Bolts noted "~~5/4~~" shall be changed to "**5/8**"

Electrical:

Item 1: Approved Light Substitutions

See attached: Fixture A, Fixture B, Fixture C, Fixture E & Fixture X2

END OF ADDENDUM (total of 13 pages including drawings)